



# A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210  
Phone (207) 784-5354 website [www.allaboratory.com](http://www.allaboratory.com)

## Laboratory Report

Children's Center-Early  
Intervention and  
1 Alden Avenue  
Augusta, ME 04330

Date Printed: 05/16/2023  
Work Order #: 2305-00832  
Client Job #: 2055  
Date Received: 05/04/2023  
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the \* symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

**A & L Laboratory:**  
*Identified by ME in Analyst Column*  
155 Center Street, Auburn, Maine 04210  
[www.allaboratory.com](http://www.allaboratory.com)

**Granite State Analytical Services LLC:**  
*Identified by NH in Analyst Column*  
22 Manchester Road, Derry, NH 03038  
[www.granitestateanalytical.com](http://www.granitestateanalytical.com)

**Nashoba Analytical:**  
*Identified by MA in the Analyst Column*  
31A Willow Road, Ayer, MA 01432  
[www.nashobaanalytical.com](http://www.nashobaanalytical.com)

### ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- DF: "Dilution factor" means the ratio of the volume of the sample to the volume of the final (dilute) solution.
- MDL: "Minimum Detection Limit" means the minimum result which can be reliably discriminated from a blank with a predetermined confidence level.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

### SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche  
Laboratory Director

A & L Laboratory: Accreditations: Maine ME00021, New Hampshire 2501, Maine Radon Registration ID # SPC20  
Granite State Analytical Services, LLC: Accreditations: New Hampshire 1015; Maine NH00003;  
Massachusetts M-NH0003; Rhode Island 101513; Vermont VT-101507  
Nashoba Analytical: Accreditations: Massachusetts M-MA1118



# A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210  
 Phone (207) 784-5354 website www.allaboratory.com

## CERTIFICATE OF ANALYSIS FOR DRINKING WATER

**DATE PRINTED:** 05/16/2023  
**CLIENT NAME:** Children's Center-Early Intervention and

**CLIENT ADDRESS:** 1 Alden Avenue  
 Augusta, ME 04330

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

**METHOD:** EPA 200.8  
**EPA ACTION LEVEL:** 15 ppb  
**MAINE GUIDELINE:** 4 ppb  
**REPORTING LIMIT:** 1 ppb

**DATE AND TIME RECEIVED:** 05/04/2023 09:10AM  
**ANALYSIS PACKAGE:** Maine Schools-Lead  
**RECEIPT TEMPERATURE:** 19° CELSIUS  
**CLIENT JOB #:** 2055

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2305-00832-001	Special Purpose Private School sink	I	OT	05/03/2023 06:49AM	<1	ppb			DG-NH	05/05/2023 05:37PM
2305-00832-002	Bursting Blossoms classroom sink	I	OT	05/03/2023 06:51AM	<1	ppb			DG-NH	05/05/2023 05:41PM
2305-00832-003	Bursting Blossoms bathroom sink	I	OT	05/03/2023 06:51AM	<1	ppb			DG-NH	05/05/2023 05:45PM
2305-00832-004	Stepping Stones II classroom sink	I	OT	05/03/2023 06:55AM	<1	ppb			DG-NH	05/05/2023 05:49PM
2305-00832-005	Stepping Stones II bathroom sink	I	OT	05/03/2023 06:55AM	<1	ppb			DG-NH	05/05/2023 06:04PM
2305-00832-006	Stepping Stones III adult sink	I	OT	05/03/2023 06:57AM	<1	ppb			DG-NH	05/05/2023 06:08PM
2305-00832-007	Stepping Stones III bathroom sink	I	OT	05/03/2023 06:57AM	1.1	ppb			DG-NH	05/05/2023 06:12PM
2305-00832-008	Growing Sprouts adult sink	I	OT	05/03/2023 07:05AM	<1	ppb			DG-NH	05/05/2023 06:15PM
2305-00832-009	Growing Sprouts children's sink	I	OT	05/03/2023 07:05AM	<1	ppb			DG-NH	05/05/2023 06:19PM
2305-00832-010	Growing Sprouts bathroom sink	I	OT	05/03/2023 07:05AM	<1	ppb			DG-NH	05/05/2023 06:31PM
2305-00832-011	Hummingbirds children's sink	I	OT	05/03/2023 07:03AM	<1	ppb			DG-NH	05/05/2023 06:35PM
2305-00832-012	Hummingbirds adult sink	I	OT	05/03/2023 07:03AM	<1	ppb			DG-NH	05/05/2023 06:39PM
2305-00832-013	Kitchen-3 basin sink	I	KF	05/03/2023 07:02AM	<1	ppb			DG-NH	05/05/2023 06:54PM
2305-00832-014	Hallway water cooler	I	DWF	05/03/2023 06:57AM	<1	ppb			DG-NH	05/05/2023 06:58PM
2305-00832-015	Hallway children's bathroom sink	I	OT	05/03/2023 06:52AM	<1	ppb			DG-NH	05/05/2023 07:01PM
2305-00832-016	Hallway adult bathroom sink	I	OT	05/03/2023 06:56AM	<1	ppb			DG-NH	05/05/2023 07:05PM
2305-00832-017	Admin bathroom sink	I	OT	05/03/2023 06:49AM	<1	ppb			DG-NH	05/05/2023 07:09PM
2305-00832-018	Kitchen small sink	I	KF	05/03/2023 07:02AM	3.8	ppb			DG-NH	05/15/2023 02:01PM

Rebecca L. Labranche  
 Laboratory Director